

Walkthrough Inspection Checklist

Name: Middlefield!	Memorial	School
Room or Area: Poof	Date Completed:	01-04-24
Signature:		

1.	GROUND LEVEL	Yes	No	N/A
1a.	Ensured that ventilation units operate properly	🖎		
1b.	Ensured there are no obstructions blocking air intakes	च		
1c.	Checked for nests and droppings near outdoor air intakes	≥		
1d.	Determined that dumpsters are located away from doors, windows, and			
	outdoor air intakes	🗉		
1e.	Checked potential sources of air contaminants near the building	-	_	
	(chimneys, stacks, industrial plants, exhaust from nearby buildings)	🗷		
1f.		⊜		
1g.	Minimized pesticide application	🌌		
1h.	Ensured that there is proper drainage away from the building (including	net		
223	roof downspouts)	🛥	_	_
li.	Ensured that sprinklers spray away from the building and outdoor air intakes	26		
1.	- 1 to the second that		_	_
lj.	they are cleaned regularly	選		
	they are element regularly minimum.			
2.	ROOF			
TI71.	ile on the roof, consider inspecting the HVAC units (use the Ventilation Che	cklis	t).	
2a.	Ensured that the roof is in good condition	(E)		0 0 0
2b.	Checked for evidence of water ponding	qa		
2c.	Checked that ventilation units operate properly (air flows in)	ISS	٥	
2d.	Ensured that exhaust fans operate properly (air flows out)	iner		
2e.	Ensured that air intakes remain open, even at minimum setting	GP	٥	N 1270
2f.	Checked for nests and droppings near outdoor air intakes Ensured that air from plumbing stacks and exhaust outlets flows away	43	_	_
2g.	from outdoor air intakes	🗃		
	from outdoor air intakes			
3.	ATTIC			
	Checked for evidence of roof and plumbing leaks	瞬		
3a.	Checked for birds and animal nests	- E	_	
30.	Checked for birds and animal nests			10-000
4	GENERAL CONSIDERATIONS			
4a.	Ensured that temperature and humidity are maintained within acceptable ranges			
11	Ensured that no obstructions exist in supply and exhaust vents	S		
40.	Checked for odors	20		
4d	Checked for signs of mold and mildew growth	త		

Instructions

- Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- Keep the Background Information and make a copy of the checklist for future reference.
- Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

4.	GENERAL CONSIDERATIONS (continued)	Yes	No	N/A
4e.	Checked for signs of water damage	. H		
4f.	Checked for evidence of pests and obvious food sources	. 20		
4g.	Noted and reviewed all concerns from school occupants	. ď		
5.	BATHROOMS AND GENERAL PLUMBING			
5a. 5b.	Ensured that bathrooms and restrooms have operating exhaust fans Ensured proper drain trap maintenance:	E		<u> </u>
	Water is poured down floor drains once per week (approx. I quart of water) 21		
	Water is poured into sinks at least once per week (about 2 cups of water)			
	Toilets are flushed at least once per week			
6.	MAINTENANCE SUPPLIES			
6а.	Ensured that chemicals are used only with adequate ventilation and when			
	building is unoccupied	M		
6b.	Ensured that vents in chemical and trash storage areas are operating			c-a.
	properly	. <u>M</u>		
6c.	Ensured that portable fuel containers are properly closed	🗷		\Box
6d.	Ensured that power equipment, like snowblowers and lawn mowers, have been serviced and maintained according to manufacturers' guidelines	Ø		
7.	COMBUSTION APPLIANCES			
70	and a six of the six o	🗷		
7a.	Ensured that combustion appliances have flues or exhaust hoods			
70.	Checked for leaks, disconnections, and deterioration	. a		ā
70.	Ensured there is no soot on inside or outside of flue components	20		
/ u .	Ensured incre is no soot on inside of odiside of the components.		_	_
	OTHER			
8a.	Checked for peeling and flaking paint (if the building was built before	itear"	_	,-m
	1980, this could be a lead hazard)			
86.	Determined date of last radon test	🗗		

NOTES